

**CITY OF PLATTSBURG
114W. MAPLE
PLATTSBURG, MO. 64477
816-539-2148**

APPLICATION FOR PRIVATE SWIMMING POOL PERMIT
ALL PRIVATE SWIMMING POOLS MORE THAN TWENTY FOUR (24)
INCHES DEEP REQUIRES A PERMIT

DATE: _____

APPLICANT NAME: _____

ADDRESS: _____

TELEPHONE NUMBER: _____

INSTALLER NAME: _____

ADDRESS: _____

TELEPHONE NUMBER: _____

1. POOL TYPE: ___ INGROUND ___ ABOVE GROUND

2. POOL DEPTH AT DEEPEST POINT: _____

3. POOL SIZE: _____ x _____

4. TYPE BARRIER: ___ FENCE FOURTY EIGHT (48) INCHES MINIMUM
 ___ CHAINLINK ___ PICKET ___ PRIVACY

 ___ FOUR (4) FOOT DECK AROUND POOL WITH FOURTY
 EIGHT (48) INCH RAILING AND SPINDLES FOUR (4)
 INCH ON CENTER

5. OWNER TO PROVIDE THE CITY A COPY OF THE MANUFACTURES
SPECIFICATIONS AND INSTALLATION INSTRUCTIONS, THOSE SHALL
COMPLY WITH THE 2006 INTERNATIONAL RESIDENTIAL CODE
STANDARDS, CHAPTER FOURTY ONE (41) AND APPENDEX A. IF THEY DO
NOT THE INTERNATIONAL CODE STANDARDS SHALL BE USED.

6. FEE: _____ PERMIT NO. _____

Good for you, Plattsburg!

**CITY OF PLATTSBURG
114 W. MAPLE
PLATTSBURG, MO. 64477
(816) 539-2148**

PRIVATE SWIMMING POOL

ALL PRIVATE SWIMMING POOLS THAT ARE TWENTY FIVE (25) INCHES OR MORE DEEP REQUIRE A PERMIT AND MUST COMPLY WITH THE 2006 INTERNATIONAL RESIDENTIAL CODE AND BE INSTALLED AS REQUIRED IN CHAPTER FOURTY ONE (41) AND APPENDEX G.

ALL PRIVATE SWIMMING POOLS THAT ARE TWENTY FIVE (25) INCHES OR MORE DEEP MUST BE INCLOSED BY A FOUTY EIGHT (48) INCH FENCE AS REQUIRED BY THE CITY OF PLATTSBURG, SUBDIVISION REGULATIONS, ARTICLE V, SUPPLEMENTARY REGULATIONS SECTION F.

SEE THE POOL INSPECTION CHECK- LIST FOR BARRIER AND ELECTRICAL REQUIREMENTS. PLEASE CONTACT CITY HALL IF YOU HAVE MORE QUESTIONS MONDAY – THURSDAY 7:30 AM – 4:30 PM.

**RESPECTFULLY:
JERRY HOPKINS**

GOOD FOR YOU, PLATTSBURG!

City of Plattsburg
□ 114 W. Maple
Plattsburg, Mo. 64477
(816) 539-2148

Pool Inspection Checklist

Barrier Requirements:

- The top of the barrier must be at least 48 inches above grade
- The maximum space between bottom of barrier and grade level shall be 2 inches
- On an above-ground pool where the barrier is mounted on top of the pool structure, the spacing between the bottom of the barrier and the top of the pool structure shall be a maximum of 4 inches.
- Openings between spindles in the barrier shall not allow passage of a 4 inch sphere
- Spacing between spindles shall not exceed 3 3/4 inches in width (Decorative cutouts apply also)
- Chain link fence used as a barrier shall have maximum mesh size of 3 3/4 inches
- Gates shall be equipped to accommodate a locking device
- Gate shall have a self-latching device where the self-latching device is placed less than 54 inches from bottom of gate then 1) the release mechanism must be located on the pool side of the gate at least 3 inches below top of gate and 2) barrier shall have no opening greater than ½ inch within 18 inches of the release mechanism.

Electrical Requirements:

- All metal less than 5 feet from pool must be bonded with 8 AWG copper
- Only pool-associated conduit within 5 feet of inside wall of pool
- Non-pool associated conduit o.k. if space is limited & in rigid metal at minimum 6 inch deep or PVC 18 inches deep
- Overhead wire can be no closer than 18 feet from water
- Overhead wire can be no closer than 14 feet from diving board
- Maximum length of cord on pool equipment is 3 feet with 12 AWG ground
- GFCI-protected lighting must be less than 10 feet from water's edge
- GFCI outlets cannot be closer than 10 feet and farther than 20 feet from pool walls
- No poolside outlets placed less than 10 feet from water's edge
- All grade-accessible outlets must be GFCI-protected excluding inside house
- Pump Motor-if greater than 5 feet and less than 10 feet from pool walls must have a twist lock receptacle and GFCI protection

Good for you, Plattsburg!